


The PH internal services i.e. G.P. pipes & C.I. pipes are passing through the proposed lift well. The applicant, therefore, may have to arrange the shifting of these services at an appropriate location/place at his own cost before taking up the installation of lift at proposed location.

Lifts can be provided in this category as far as structural aspect is concerned subject to shifting of services coming in the area of lift-tunnels. It is required to be designated for lift and re-routing of that area for lift is to be done under the supervision and guidance of Structural Engineer Empowered by C.E.D. Admin.

EE-VI(PH)

It has been observed that many electric supply cables & telephone cables are passing along the proposed lift well. The applicant may have to shift these services at his own cost from the current location. Further Sp. of lift/well may be taken as per National Building Code (NBC)/specifications of C.E.D. for lifts.



GROUND FLOOR PLAN

Lift proposal is Architecturally O.K. However its location & any additional area be seen by T.P. wing. *1406/24*

The lift can be accommodated within the CMB area / layout plan subject to structural stability, electrical, architectural aspects & area as available for need based requirements as no zoning is available.

NOTE:
NO. OF PERSONS - 13
LIFT WELL SIZE - 2500 X 1500 mm
(AS PER NBC)
DEPTH OF LIFT PIT - 1500 mm
ENTRANCE - 900 mm

CHANDIGARH HOUSING BOARD

NOTES:-

1. THIS DRAWING IS THE PROPERTY OF THE CHD. AND MUST NOT BE COPIED, ALTERED OR TRACED IN WHOLE OR IN PART WITHOUT THE PERMISSION OF THE BOARD IN WRITING.
2. NO RAIN WATER PIPE, SOIL PIPE, VENTILATING PIPE OR ANY OTHER PLUMBING WORK SHALL BE EXPOSED TO VIEW ON ANY FACE OF THE BUILDING.
3. NO APPLIED DECORATION OF ANY SORT LIKE THE CROSS, SWASTIKA ETC. SHALL BE PERMITTED ON THE EXTERNAL FACE OF THE BUILDING OR ON THE BOUNDARY WALL.
4. THE COST OF COMMON WALLS SHALL BE SHARED PROPORTIONATELY BY THE RESPECTIVE ALLOTTEES.
5. NO ADVERTISEMENT IN WHAT-SO-EVER FORM, KIND OR MANNER, WHETHER THE NAME OF THE PERSON OR A FIRM SHALL BE PERMITTED ON THE FACE OF THE BUILDING OR ON OR ALONG THE BOUNDARY WALL EXCEPT THE NUMBER OF THE PREMISES DISPLAYED IN PAINTED NUMERALS ON SPACE ASSIGNED FOR THE PURPOSES.
6. FOR ANY OTHER DETAIL / NOTES REF. DRG. NO. 1, 2, 3 JOB NO. 162
7. ADDITIONAL CONSTRUCTION HAS BEEN SHOWN HAS MATCHED

JOINERY DETAIL :-

TYPE	SIZE	CILL
D01	8'-10" X 6'-4"	
D02	7'-4" X 6'-0"	
D	3'-0" X 6'-0"	
D1	3'-4" X 6'-0"	
D2	3'-4" X 6'-0"	
D3	3'-0" X 6'-0"	
D4	2'-7" X 6'-0"	
D5	2'-3" X 6'-0"	
D6	6'-0" X 6'-0"	2'-4"
D3/V	3'-0" X 7'-7"	
W3	5'-3" X 3'-4"	3'-4"
W4	4'-6" X 4'-0"	2'-4"
W5	6'-0" X 4'-0"	2'-4"
W6	2'-0" X 6'-0"	5'-2"
W7	2'-3" X 3'-7"	5'-2"
W8	2'-3" X 3'-4"	5'-2"
W9	2'-3" X 4'-0"	2'-3"
W10	2'-0" X 6'-1"	5'-2"
W11	1'-3" X 3'-1"	5'-2"

Nalini Sharma
Architect.

18/07/23

SCALE: 1/8" = 1'-0"

DATE: 12-11-2014

DRAWN BY: *[Signature]*

162

21

CHECKED BY:

STANDARD DESIGN OF G.H.S. IN WEST OF SECTOR - 38 CHANDIGARH. (U.T.) H.I.G. (LOWER) GROUND FLOOR PLAN

CHANDIGARH HOUSING BOARD

NOTES:-

1. THIS DRAWING IS THE PROPERTY OF THE CHD. AND MUST NOT BE COPIED, ALTERED OR TRACED IN WHOLE OR IN PART WITHOUT THE PERMISSION OF THE BOARD IN WRITING.
2. NO RAIN WATER PIPE, SOIL PIPE, VENTILATING PIPE OR ANY OTHER PLUMBING WORK SHALL BE EXPOSED TO VIEW ON ANY FACE OF THE BUILDING.
3. NO APPLIED DECORATION OF ANY SORT LIKE THE CROSS, SWASTIKA ETC. SHALL BE PERMITTED ON THE EXTERNAL FACE OF THE BUILDING OR ON THE BOUNDARY WALL.
4. THE COST OF COMMON WALLS SHALL BE SHARED PROPORTIONATELY BY THE RESPECTIVE ALLOTTEES.
5. NO ADVERTISEMENT IN WHAT-SO-EVER FORM, KIND OR MANNER, WHETHER THE NAME OF THE PERSON OR A FIRM SHALL BE PERMITTED ON THE FACE OF THE BUILDING OR ON OR ALONG THE BOUNDARY WALL EXCEPT THE NUMBER OF THE PREMISES DISPLAYED IN PAINTED NUMERALS ON SPACE ASSIGNED FOR THE PURPOSES.
6. FOR ANY OTHER DETAIL / NOTES REF. DRG. NO. 1, 2, 3 JOB NO. 162
7. ADDITIONAL CONSTRUCTION HAS BEEN SHOWN HAS HATCHED

JOINERY DETAIL :-

TYPE	SIZE	CILL
DG1	8'-10" X 8'-4"	
DG2	7'-6" X 6'-6"	
D	3'-6" X 6'-6"	
D1	3'-4" X 6'-6"	S.R.
D2	3'-4" X 6'-6"	
D3	3'-0" X 6'-6"	
D4	2'-7" X 6'-6"	
D5	2'-3" X 6'-6"	
W1	6'-0" X 6'-0"	2'-4"
D3V	3'-0" X 9'-7"	
W3	5'-3" X 3'-4"	3'-4"
W4	4'-8" X 4'-8"	2'-4"
W5	6'-0" X 4'-8"	2'-4"
W6	2'-0" X 6'-0"	5'-2"
W7	2'-3" X 3'-7"	5'-2"
W8	2'-3" X 3'-4"	5'-2"
W9	2'-3" X 4'-8"	2'-3"
W10	2'-6" X 6'-1"	5'-2"
W11	1'-3" X 3'-1"	

Nalini Sharma
Architect

18/07/23

SCALE : 1/4" = 1'-0"

DATE :- 12-11-2014

DRAWN BY: *Ravi*

162


22

CHECKED BY:

**STANDARD DESIGN OF G.H.S.
IN WEST OF SECTOR - 38
CHANDIGARH. (U.T.)
H.I.G. (LOWER)**

FIRST FLOOR PLAN

NOTE:
NO. OF PERSONS - 13
LIFT WELL SIZE - 2500X1900mm
(AS PER NBC)
DEPTH OF LIFT PIT - 1500mm
ENTRANCE - 900mm



FIRST FLOOR PLAN

CHANDIGARH HOUSING BOARD

NOTES:-

1. THIS DRAWING IS THE PROPERTY OF THE CHD, CHD. AND MUST NOT BE COPIED, ALTERED OR TRACED IN WHOLE OR IN PART WITHOUT THE PERMISSION OF THE BOARD IN WRITING.
2. NO RAIN WATER PIPE, SOIL PIPE, VENTILATING PIPE OR ANY OTHER PLUMBING WORK SHALL BE EXPOSED TO VIEW ON ANY FACE OF THE BUILDING.
3. NO APPLIED DECORATION OF ANY SORT LIKE THE CROSS, SWASTIKA ETC. SHALL BE PERMITTED ON THE EXTERNAL FACE OF THE BUILDING OR ON THE BOUNDARY WALL.
4. THE COST OF COMMON WALLS SHALL BE SHARED PROPORTIONATELY BY THE RESPECTIVE ALLOTTEES.
5. NO ADVERTISEMENT IN WHAT-SO-EVER FORM, WORD OR MANNER, WHETHER THE NAME OF THE PERSON OR A FIRM SHALL BE PERMITTED ON THE FACE OF THE BUILDING OR ON OR ALONG THE BOUNDARY WALL EXCEPT THE NUMBER OF THE PREMISES DISPLAYED IN PAINTED NUMERALS ON SPACE ASSIGNED FOR THE PURPOSES.
6. FOR ANY OTHER DETAIL / NOTES REF. DRG. NO. 123 JOB NO. 162
7. ADDITIONAL CONSTRUCTION HAS BEEN SHOWN HAS HATCHED

JOINERY DETAIL:-

TYPE	SIZE	CILL
D01	5'-10" X 6'-4"	
D02	7'-6" X 6'-0"	
D1	3'-0" X 6'-0"	
D2	3'-4" X 6'-0"	S.R.
D3	3'-0" X 6'-0"	
D4	2'-7" X 6'-0"	
D5	2'-3" X 6'-0"	
D6	6'-0" X 6'-0"	2'-4"
D3V	3'-0" X 5'-7"	
D3	5'-3" X 3'-4"	3'-4"
D4	4'-6" X 4'-6"	2'-4"
D5	6'-0" X 4'-6"	2'-4"
D6	2'-0" X 6'-0"	2'-4"
D7	2'-3" X 3'-7"	5'-2"
D8	2'-3" X 3'-4"	5'-2"
D9	2'-3" X 4'-6"	5'-2"
D10	2'-6" X 6'-1"	2'-3"
D11	1'-3" X 3'-1"	5'-2"


■ - TO BE DEMOLISHED

18/07/23
Nalini Sharma
Architect

SCALE: 1/4" = 1'-0"
DATE: 12-11-2014
DRAWN BY: *KL*
CHECKED BY: *KL*
JOB NO. 162
DRG. NO. 23

STANDARD DESIGN OF G.H.S.
IN WEST OF SECTOR - 38
CHANDIGARH. (U.T.)
H.I.G. (LOWER)
SECOND FLOOR PLAN

NOTE:
NO. OF PERSONS - 13
LIFT WELL SIZE - 2500 X 1900 mm
(AS PER NBC)
DEPTH OF LIFT PIT - 1500 mm
ENTRANCE - 900 mm



SECOND FLOOR PLAN

NOTES:-

- JOINERY DETAIL :-**

TYPE	SIZE	CILL
D01	8'-10" X 8'-4"	
D02	7'-6" X 8'-0"	
D	3'-0" X 6'-0"	
D1	3'-4" X 8'-0"	
D2	3'-4" X 8'-0"	S.R.
D3	3'-0" X 8'-0"	
D4	2'-7" X 8'-0"	
D5	2'-3" X 8'-0"	
D11	8'-0" X 8'-0"	2'-4"
D3/V	3'-0" X 7'-3"	
D3	8'-0" X 7'-4"	3'-4"
D4	4'-0" X 4'-6"	2'-4"
D5	8'-0" X 4'-0"	2'-4"
D6	2'-0" X 6'-0"	
D7	2'-3" X 3'-7"	5'-2 1/2"
D8	2'-3" X 3'-1"	5'-2 1/2"
D9	2'-3" X 4'-5"	8'-2 1/2"
D10	2'-6" X 6'-1"	2'-3"
D11	1'-3" X 3'-1"	5'-2 1/2"

Nalini Sharma
Architect

SCALE: 1/4" = 1'-0"

DRAWN BY

DRAWN BY Kene

CHECKED BY _____

**STANDARD DESIGN OF G.H.S.
IN WEST OF SECTOR - 38
CHANDIGARH. (U.T.)
H.I.G. (LOWER)**

TERRACE FLOOR PLAN



NOTE:
NO.OF PERSONS- 13
LIFT WELL SIZE- 2500X1900mm
(AS PER NBC)
DEPTH OF LIFT PIT- 1500mm
ENTRANCE - 900mm